



NOTES:

1. 4"X4" POST SHALL BE PRESSURE TREATED CONFORMING TO SECTION 82-3 OF CALTRANS SPECIFICATIONS, EXCEPT THAT REDWOOD SHALL NOT BE ALLOWED.
2. POSTS SHALL BE BACKFILLED WITH COMPACTED EARTH.
3. 2"X6" CROSS BOARDS SHALL BE S4S DOUGLAS FIR FASTENED TO POSTS WITH 1/2" GALVANIZED BOLTS, WASHERS AND NUTS COUNTERSUNK AT BOTH ENDS.
4. BARRICADE SHALL BE PAINTED WHITE (1 COAT PRIMER AND 2 COATS ENAMEL) AFTER ERECTION.

COUNTY OF SONOMA  
DEPARTMENT OF TRANSPORTATION  
AND PUBLIC WORKS

SIDEWALK BARRICADE

DATE: NOV 2009

REVISED:

APPROVED BY:

SCALE:

DRAWING NO.

JH

NONE

229